

September 5th, 2024

A – Addendum #4

RFP – 2024 WWTP Dewatering Polymer Procurement

QUESTION	ANSWER
<p>For Addendum #3, the "solids concentration" values in m3/day are listed as flow rates, not as solids concentrations. The values we all need will be either mg/L (similar to the MLSS values) or as % solids. Typically primary solids are 5-7% solids and the TWAS is 3-5% solids, but we need these values, even if they're averages, in order to calculate our dosages and produce a testing report.</p> <p>Are those values available?</p>	<p>The RMOW does not collect the values you are seeking.</p>
<p>On the bid, the tote volume needed is mentioned to be 1040.</p> <p>Is 1040 KG tote mandatory, or can RMOW accept other tote volumes?</p>	<p>The plant's polymer platform can accommodate a tote with a base measuring 1000 mm by 1220 mm or 40 inches by 48 inches.</p>

End of Addendum